



CITY of NORTH OLMSTED

Mayor Kevin M. Kennedy

Division of Building

A 5200 Dover Center Road | North Olmsted, Ohio 44070 P 440-777-8000 F 440-777-5889

EMERGENCY GENERATORS

Please submit the following information:

Address: _____

Applicant: _____

Hours of Exercise: _____

Abuts Residential: Yes No

Maximum Permissible Sound Levels by Receiving Land Use: See attached

Please attach a site plan showing the proposed location, specifications showing the type of unit and output sound level at 23 feet to be an average of _____ dBA.

This information will be reviewed by Safety Department. Once it is approved, an electrical and building permit for the gas line will be required.

MAXIMUM PERMISSIBLE SOUND LEVELS BY RECEIVING LAND USE.

No person shall operate, cause to be operated or permit on private property any source of sound in such a manner as to create a sound level which exceeds the limits set forth for the receiving land use category in Table 1 when measured at or within the property boundary of the receiving land use.

Table 1. SOUND LEVELS BY RECEIVING LAND USE

Receiving Land Use Category	Time	Sound Level Limit dBA
Residential; two-family; multi-family high rise	8:00 a.m. to 9:00 p.m.	60
Residential, public space, open space or institutional	8:00 p.m. to 9:00 a.m.	50
General retail business or local retail business	At all times	65
Industrial	At all times	70

(Ord. 77-126. Passed 5-2-78.)