

Sanitary Sewer Smoke Testing Frequently Asked Questions

What exactly is a Smoke Test?

A Crew from The City of North Olmsted Wastewater Treatment Plant will use a high capacity blower technique to test each sewer line with smoke. Smoke blowers are placed on manholes and smoke is blown through the sewer system. Any location where smoke is identified during the test, except plumbing vent stacks, is a potential I/I source for storm water to enter the sewer systems. These locations will be documented via marking paint, flags, GPS locations, pictures, and sketches.

What is the benefit of performing a Smoke Test?

Smoke testing is one technique utilized to identify sections of sewers that may exhibit inflow during heavy rainfall. Smoke testing is best used to detect inflow sources such as roof downspouts, driveways, yard and area drains, foundations drains, faulty connections, and storm water drainage system cross connections. It can also detect structural damages and leaking joints in sewer pipes.

How will residents know when the Smoke Testing will be performed in their neighborhoods?

At least 2 weeks prior to beginning the smoke testing, WWTP will mail notices to all homes/ buildings on the streets to be smoke tested. In addition, the department will remind customers via door hangers at least 24 to 48 hours in advance of the actual test day (weather depending).

How are city crews recognizable in the field?

WWTP personnel are uniformed and carry identification. Crew members operate from vehicles with proper signage for ease of recognition.

Is the smoke that is used hazardous?

The smoke that comes out of the vent stacks on houses or holes in the ground is non-toxic. It does not create fire hazard. The City of North Olmsted and/or local police & fire departments will be made aware of the test areas and schedule.

Do residents have to do anything to prepare their homes for Smoke Testing?

Plumbing drain traps need to be filled with water to prevent the smoke from entering the building. Run the faucet for 30-60 seconds or pour about 3 cups of water in the floor and sink drains, filling the traps. If smoke does enter, the resident should consult a licensed plumber. If smoke from the testing can enter through faulty plumbing, the potential exists for dangerous sewer gases to also enter the home.

Does the resident need to be home when the Smoke testing is performed?

Homeowners do not need to be home and at no time will field crews need to enter the residence. Field inspectors will be documenting the testing, taking photos and measuring distances so that the defects may be repaired at a later date.

What happens after the Smoke Testing has been completed?

WWTP will notify residents and/or property owners who need to make corrections with a letter explaining the nature of any defect found, ways to correct it, and a list of licensed sewer contractors who can make correction, if need be. Again, most corrections can be easy fixes, such as disconnecting a downspout from the ground and letting the water flow above ground away from the home.